

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/AGR/26/09/914

Dated: 06/09/2026

It is certified that an inspection team headed by Mr. VIPIN AGARIYA (A.E.) (Name of Officers with designation) from U.P. Jal Nigam (Rural), Agra, inspected the SHRI RAMJILAL CONVENT SCHOOL, LAKHANPUR, SIKANDRA, AGRA (Name & Address of the school) on 03/09/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no UPJN/AGR/26/09/914 dated 06/09/2026 of Regional Level Water Analysis Laboratory (UP JAL NIGAM) certified that the SHRI RAMJILAL CONVENT SCHOOL, LAKHANPUR, SIKANDRA, AGRA (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year from issue date

सहायक अभियन्ता

खण्ड कार्यालय

Signature with Seal: उपप्र. जल निगम (ग्रामीण)

Name: Mr. Vipin Agariya आगरा


Designation: Assistant Engineer

Name & Address of the Office / Department:

Regional Level Water Analysis Laboratory

To

SHRI RAMJILAL CONVENT SCHOOL,
LAKHANPUR, SIKANDRA,
AGRA





Regional Water Testing Laboratory

Address: 4/4 Sanjay Place U.P. Jal Nigam (Rural) Agra, 282002



TEST REPORT

Report No:	UPJN/AGR/26/09/914	Issue Date:	06/09/2026	Page No	1
Remark :					

Customer Details

Office Name and Address	SHRI RAMJILALCONVENT SCHOOL LAKHANPUR, SIKANDRA , AGRA
Ref Letter No & Date	DATE 03/09/2026

Basic details of sample

District	AGRA	Block/City	LAKHANPUR, SIKANDRA , AGRA
Gram Panchayat	-	Village/city	AGRA
Water Source	RO Water	Location	SHRI RAMJILALCONVENT SCHOOL
Quantity of Sample	1 Lt.	Sample No.	01
Receiving Date	03/09/2026	Date of Collection	03/09/2026
Sample Depositor	-	S. Collector	-
Analysis Start Date	03/09/2026	Sampling Method	As per IS 17614: Part 1: 2021
		Analysis Completion Date:	05/09/2026

Technical Data of Analysis

S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.42	6-8.5	6.5-8.5	IS 3025 (Part 11):2022(Electrometric method)
2	Turbidity NTU	0.529	1	5	IS 3025 (Part 10):2023 (Nephelometric Method)
3	Total Dissolved Solid mg/L	132	500	2000	IS 3025 (Pt 16):2023 (Gravimetric Method)
4	Fluoride mg/L	0.244	1	1.5	APHA 24 th Edition 4500-F Method C (Electrode method) 2023
5	Total Hardness mg/L	30	200	600	IS 3025 (Part 21):2023(EDTA Method)
6	Total Alkalinity mg/L	42	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	18	250	1000	IS 3025 (Part 32):2025 (Argentometric method)
8	Iron mg/L	--	1	1	APHA 24 th Edition 3500-Fe Method B (Phenanthroline Method) 2023
9	Sulphate mg/L	02	200	400	APIIA 24 th Edition 4500-SO4 Method E (Turbidity Method) 2023
10	Calcium mg/L	14	175	200	IS 3025 (Part 40):2024(EDTA Titrimetric Method)
11	Magnesium mg/L	3.88	30	100	IS 3025 (Part 46):2023(Volumetric Method)
12	Color (Hazen)	1	5	15	IS3025 Edition(Part 4) Color (Visual Comparison Method)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 2023 (Qualitative Method)
14	Nitrate (mg/l)	nill	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)

Note:

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests

TEST REPORT

